

 <p>CITY OF MILPITAS Office of Building Safety 455 E. Calaveras Blvd. Milpitas, CA 95035 408-586-3240 www.milpitas.gov</p>	Policy:	BDP-EL01
	Effective Date:	1/1/2011
	Proposed by:	
	Last Reviewed/ Revised:	3/8/2023
	Reviewed/ Revised by:	JDS
	Approved By:	Building Official
ACCESS & ENTRANCE TO ELECTRICAL EQUIPMENT IN MULTI-TENANCY BUILDING		

In conformance with sections 90.4 and 110.26(C) of the 2022 California Electrical Code, the following interpretation is provided:

“In multiple tenancy buildings, the following access and entrance to electrical equipment are acceptable:

1. All required entrances must be located on the exterior of the building, or
2. Interior public corridor leading directly to building exit.

In single tenancy buildings, the required entrances may be a combination exterior/interior”