



## CITY OF MILPITAS

Office of Building Safety  
455 E. Calaveras Blvd.  
Milpitas, CA 95035  
408-586-3240  
[www.milpitas.gov](http://www.milpitas.gov)

**Policy:** **BDP-EL07**

Effective Date: 1/1/2014

Proposed by: LS

Last Reviewed/ Revised: 3/8/2023

Reviewed/ Revised by: JDS

Approved By: Building Official

### PROTECTION OF WORKING SPACE CLEARANCES AT ELECTRICAL EQUIPMENT

As per 2022 CEC sec. 110.26 (B), “working space [for electrical equipment] shall not be used for storage and when normally enclosed live parts are exposed for inspection or servicing, the working space, if in a passageway or general open space, shall be suitably guarded.”

To properly identify guarded area, provide label on the equipment stating that minimum clear distance, as identified by 2022 CEC sec. 110.26(A), shall be maintained clear and unobstructed. The depth of the working space shall be minimum 36" and the width is 30" or the width of the equipment, whichever is greater.