



## CITY OF MILPITAS

Office of Building Safety  
455 E. Calaveras Blvd.  
Milpitas, CA 95035  
408-586-3240  
[www.milpitas.gov](http://www.milpitas.gov)

Policy:	BDP-EL02
Effective Date:	3/21/1996
Proposed by:	
Last Reviewed/ Revised:	3/8/2023
Reviewed/ Revised by:	JDS
Approved By:	Building Official

### MULTIPLE TENANCY BRANCH CIRCUITS AND DISCONNECTS

Official Interpretation 2022 CEC Multiple Tenancy Branch Circuits and Disconnects

In conformance with sections 90.4, 230.72 (C), and 240.24 (A) and (B) of the 2022 California Electrical Code, the following interpretation is provided:

- 1) **Branch circuits shall not be shared between tenants.**
- 2) **Where multiple tenancies occur, each tenant shall be provided with dedicated panel with approved disconnecting means and must be accessible to tenants.**