



MILPITAS FIRE DEPARTMENT
FIRE PREVENTION DIVISION

455 E. Calaveras Blvd., Milpitas, CA 95035 (408) 586-3365, FAX (408) 586-3378

INSPECTION CHECKLIST GROUP S OCCUPANCIES

Examine Housekeeping Issues

Verify that:

1. Storage of combustible materials is orderly.
2. Storage is separated from heaters or heating devices by distance or shielding.
3. Storage is at least 18 inches below sprinkler head deflector or 2 feet below ceiling in nonsprinkled areas.
4. Exits and exit enclosures are kept free from combustible materials.
5. Boiler, mechanical and electrical equipment rooms are kept free from combustible materials.
6. Any attic, under-floor and concealed spaces used for storage of combustible materials is protected on storage side as required.
7. Outside storage of combustible materials is not located within 10 feet of property line unless exception allows.
8. Combustible waste containers larger than 40 gallons have lids constructed of metal or approved combustible material.
9. Dumpsters and containers more than 40.6 cubic feet stored outside and not within 5 feet of combustible walls, openings or under eave lines.
10. Oily rags or other materials subject to spontaneous ignition are stored in a listed disposal container and removed daily as required.

Examine Miscellaneous Areas

Verify that:

1. Approved address numbers are plainly legible and visible from the street fronting the property.
2. Knox box is properly installed, if required.
3. Fire apparatus roads are unobstructed.
4. Fire apparatus roads are not less than 20 feet; with a minimum height unobstructed of 13 feet 6 inches.

Examine Fire Protection System

Verify that:

1. Fire extinguishers are installed so that their tops are no more than 5 feet above the floor if less than 40 pounds and if over 40 pounds no more than 3.5 feet above the floor.
2. Additional required extinguishers are in place.
3. All fire extinguishers have current service tag indicating service was conducted.
4. All valves on the sprinkler are electronically supervised if system has more than 20 heads.
5. All sprinkler heads or cover plates are clear of paint unless part of factory-installed paint when head was produced.
6. All fire detection, alarm, and extinguishing system are being maintained in an operative condition.
7. Records for all system inspections, tests, and maintenance for the last three years available if requested.
8. A 3-foot clearance has been maintained around all fire hydrants unless otherwise approved.
9. Fire alarm system have been properly maintained in an operative condition.
10. A 2A:20BC fire extinguisher is present within 75 feet of the pumps, dispenser or storage tank fill-pipe openings.
11. A 2A:20BC fire extinguisher is present within 30 feet of the welding area.

Examine Electrical System

Verify that:

1. Relocatable power taps are of the polarized or grounded type and are equipped with overcurrent protection and listed.
2. Relocatable power taps are directly connected to a permanently installed receptacle.
3. Relocatable power taps do not extend through walls, ceilings, floors, under doors or floor coverings, or are subject to damage.
4. Extension cords do not serve as substitute for permanent wiring.
5. Extension and flexible cords are not affixed to the structure, extended through walls, ceiling or floors.
6. Extension cords, if temporary, are plugged directly into an approved receptacle power tab or multiplug adapter.

7. Any extension cord only serves one portable appliance unless an approved multiplug extension cord is used.
8. Extension cords do not contain splices or damage.
9. Extension cords are grounded if serving grounded portable appliances.
10. Extension cord ampacity is greater than the rated ampacity of the portable appliance served by the cord.
11. Proper working spaces are being maintained in and around service equipment.
12. All electrical boxes and wiring are properly covered.
13. Temporary wiring is properly attached.
14. No multiplug adapters, such as cube adapters, unfused plug strips or any other device prohibited by the Electrical Code are present.
15. Doors into electrical control panel rooms are properly marked with a sign.

Examine Exits

Verify that:

1. The occupant load has been determined based on the use and area of the building.
2. The correct occupant load in all assembly areas has been posted near the main exit with a clearly legible permanent sign.
3. The minimum required exits are present for the occupant load.
4. Egress doors are readily openable from the egress side without the use of a key or special knowledge or effort.
5. Latches are not present for occupant load more than 50 unless it is panic hardware or fire exit hardware.
6. Exit signs are internally or externally illuminated or of approved self-luminous type.
7. Exit signs are visible under emergency illumination conditions.
8. Exit signs are no further than 100 feet from any point in a corridor.
9. Means of egress are not reduced in width along the path of egress travel.
10. Exit doorways are not less than 32 inches in width or 28 inches in existing buildings.
11. Exit signs are within 100 feet of the next visible sign.
12. Travel distances are within the maximum allowed.
13. Two exits present from each parking tier in an open parking structure.

Examine Hazardous Materials

Verify that:

1. Class I liquids in excess of 5 gallons inside or 10 gallons outside are properly permitted.
2. Storage of incompatible materials is separated properly if in containers over 5 pounds or 0.5 gallon.
3. Shelf storage of flammable and combustible liquids is orderly.
4. Class I flammable liquids are not located in the basement unless below the MAQ for open-use and the basement is sprinkled.
5. Flammable and combustible liquids used for maintenance or operation of equipment exceeding 10 gallons is stored in a liquid storage cabinet.
6. Cylinders not more than 250 cubic feet in size are present and only for maintenance or operation of equipment.
7. Hazardous Material is identified with a placard.
8. Rooms or cabinets containing compressed gases are properly identified with signage.
9. LP-gas containers present in a basement are provided the approved ventilation.

Examine Additional Fire Protection Issues

Verify that:

1. Fire doors and smoke barrier doors are not blocked or otherwise made inoperable.
2. Fire door assemblies have not been modified.
3. Swinging fire doors close from the full open position and latch automatically.
4. Horizontal and vertical sliding and rolling fire doors have been inspected and tested annually and written proof is available.
5. Magnetic hold-open devices are being maintained or are kept closed.
6. Fire-resistance-rated assemblies are protected by self-closing or automatic-closing doors of approved construction meeting the fire protection requirements of the assembly.