

Milpitas Fire Department Mobile Fueling amendments to the 2023 CA Fire Code:

V-300-2.125

Section 5707.3.3 of the California Fire Code, 2022 Edition, is amended as follows:

5707.3.3 Site plan.

A site plan shall be developed for each location or area at which mobile fueling occurs. The site plan shall be in sufficient detail to indicate the following:

1. All buildings and structures.
2. Lot lines or property lines.
3. Electric car chargers.
4. Solar photovoltaic parking lot canopies.
5. Appurtenances on-site and their use or function.
6. All uses adjacent to the lot lines of the site.
7. Fueling locations.
8. Locations of all storm drain openings and adjacent waterways or wetlands.
9. Information regarding slope, natural drainage, curbing and impounding.
10. How a spill will be kept on the site property.
11. Scale of the site plan.

Commented [MG1]: Updated to be a list format rather than in paragraph form.

V-300-12.126 Section 5707.4 of the California Fire Code, 2022 Edition, is amended to read as follows:

5707.4 Mobile fueling areas. Mobile fueling shall not occur on public streets, public ways, any residential street, or inside buildings. Fueling on the roof level of parking structures or other buildings is prohibited.

Commented [MG2]: These sections have been adopted by model code.

V-300-2.127

Section 5707.6.7 is hereby added to the California Fire Code, 2022 Edition, to read as follows:

5707.6.7 Bonding. A means for bonding the mobile fueling vehicle to the motor vehicle shall be provided. Such bonding means shall be employed during fueling operations.

NOTE:

For all other requirements reference 2023 CA Fire Code section 5707.